



› **PERFORM**

WP 4.2 - ECONOMIC EVALUATION | DINKELMAN, D. (DORIEN),
SHOEBI OMRANI, P.S. (PEJMAN), DE ZWART, H. (HIDDE)

› GOAL

- › The goal of this task is to evaluate the economy of optimization measures investigated in PERFORM.
 - › Will it produce more energy
 - › Will it produce against lower cost
- › For the economic assessment a tool is used which calculates the economy of a doublet using a discounted cashflow model.
- › Site specific economic evaluation to compare the impact of conventional and new techniques
 - › Dutch site
 - › Danish site with modified Danish subsidy regulations

ECONOMIC TOOL

CASH FLOW METHODOLOGY

- › Cash flow methodology is largely based on Dutch economic models and spreadsheets developed by ECN / TNO
- › A: Options Power or Heat (inc. ATES)
- › B: Includes simplified geothermal system input
- › C: Subsurface costs
- › D: Surface costs (power or heat)
- › E: Fiscal rules
- › F: LCOE output (also calculated: complete cashflow over doublet lifetime)

Calculation of LCOE of renewable heat and electricity				Operational choice A heat	
Geothermal Energy					
INPUT/VARIABLES				used	Value
Flowrate	1	65.0	L/s		
depth of the storage well	1	400	m		
Surface temperature	1	10	C		
waste heat temperature	1	22	C		
Economic lifetime	1	15	Years		
subsurface costs					
well costs	1	1000	eur/m depth		
well costs	1	0.40	min euro/Well		
Stimulation and other Cost	1	0	min euro/Well		
Pump investment	1	0.1	Mln euro/pump		
Number of wells	1	2	-		
subsurface capex	1	0.9	min euro		
subsurface parasitic					
COP (gross)	1	210	-		
COP (net)	1	210	-		
electricity price for driving the pumps	1	50	euro /MWhe		
Variable O&M	1	0.238	euro/MWth		
power temperature range used					
(co) heat relative starting temperature	1	0%	%		
outlet temperature power plant (Toutlet)	0	180	C		
power surface facilities					
thermal power for electricity	0	-42.820	MWth		
electric power	0	-0.551	MWe		
power Loadtime	0	8000	hours/year		
power Plant investment costs	0	2.000	min Euro/MWhe		
power Distance to grid	0	5000	m		
power Grid investment	0	80	Euro/kWe		
power Grid Connection Variable	0	100	Euro/m		
power plant capex	0	0.000	min Euro		
power Fixed O&M rate	0	1%	%		
power Fixed O&M	0	-16	kEuro/MWhe		
power Variable O&M	0	18.51958525	Euro/MWhe		
(co)heat surface facilities					
cascaded exit temperature	1	120	C		
direct heat production	1	16.302	MWth		
direct heat load hours	1	2000	hours/year		
direct heat plant investment costs	1	110	kEuro/MWth		
direct heat capex	1	1.793	min Euro		
direct heat Fixed O&M rate	1	1.0%	%		
direct heat Fixed O&M	1	2	kEuro/MWth		
direct heat Variable O&M	1	0.238095238	Euro/MWth		
complementary sales					
complementary electricity sales	1	0.00	Euro/MWth		
complementary heat sales	1	0	euro/GJ		
fiscal stimulus					
fiscal stimulus on lowering EBT	1	no	yes/no		
percentage of CAPEX for fiscal stimulus	1	42%	%		
legal max in allowed tax deduction	1	63	min Euro		
NPV of benefit to project	1	0.0	min Euro		
inflation					
Inflation	1	0%	%		
loan rate	1	6.0%	%		
Required return on equity	1	15%	%		
Equity share in investment	1	50%	%		
Debt share in investment	1	50%	%		
Tax	1	25.5%	%		
Term Loan					
Depreciation period	1	15	Year		
POWER (power,co-heat)				used	Value
levelized cost of energy (LCOE)	0	0.00	Euro/MWhe		
HEAT SHEET (heat)				Value	Unit
levelized cost of energy (LCOE)	1	4.02	Euro/GJ		
heat				value	unit
direct heat efficiency	1	1	-		
ATES heat efficiency	1	0.75	-		

› OPTIMIZATION MEASURES

› Scaling

- › Increase top side pressure (WP 2)
- › To be added: calcite inhibitor HCl (WP 4)

› Filters

- › Candle and bag particle filters, backwash drumfilter


Calculation of LCOE of renewable heat and electricity

Geothermal Energy		Case	Dutch case	Operational choice	heat	Optimization measure	Increase top side pressure
		110					
INPUTVARIABLES		used	Value	Unit	Comment		
flowrate default		1	31	l/s =	110	m3/h	
Flowrate		1	31	L/s	total flow rate which is achieved from the subsurface (measured at surface)		
depth of the storage well		1	2869	m	along hole depth (total length) of a single borehole in the subsurface		
Surface temperature		1	10.0	C	average yearly surface temperature		
waste heat temperature		1	73.0	C	production temperature (reservoir temperature, corrected for temperature losses)		
Economic lifetime		1	30	Years	lifetime for cash flow calculations		
subsurface costs							

› CASE STUDY

PIJNACKER NOOTDORP

- › Calculated geothermal power 7 MW_{th}
- › Temperature 71 °C production, 21 °C injection
- › Flow rate 110 m³/h
- › Economic lifetime 30 years
- › Example type of calculation of tool
 - › ESP replacement every 5 years → 11,94 EUR/GJ
 - › ESP replacement every 2 years → 13,01 EUR/GJ
 - › From 110 m³/h to 180 m³/h → 8.14 EUR/GJ



Costs estimation Ammerlaan doublet (ThermoGIS/general)

Drilling costs	2000 EUR/m depth
CAPEX pump	580 kEURO
OPEX pump replacement	640 kEURO
CAPEX subsurface	12,3 MEURO
Direct heat plant investment costs	300 kEUR/MWth
CAPEX surface installation	2 MEURO
OPEX variable	4,25 EUR/MWth
OPEX fixed (1% of total CAPEX)	22 kEUR/MWth


› CASE STUDY MARGRETHEHOLM

- › Calculated geothermal power 13-14 MW_{th}
- › Temperature 73°C production, 17°C injection
- › Flow rate 200 m³/h
- › Economic lifetime 30 years
- › Subsidy scheme included


› Example calculation:

- › 14 MW, 4000 h/yr → 19,67 EUR/GJ
- › 14 MW, 7000 h/yr → 11,74 EUR/GJ

Conceptual sketch
Margrethholm geothermal plant




Cost estimations



› OPTIMIZATION MEASURE

INCREASE TOP SIDE PRESSURE

- › Increase top side pressure → reduce degassing → reduce scaling
- › Data from Dutch case on flowrate and tank pressure (WP 2 and 4)
- › New flowrate and ESP power dependent on top side pressure



› **ECONOMIC EVALUATION**

SCALING INHIBITOR HCL

- › Modelling results WP4
- › Cost indication from Brenntag

› OPTMIZATION MEASURE

PARTICLE CANDLE AND BAG FILTER

- › As an alternative to adding inhibitors, improved particle and cation filters have been developed in PERFORM
- › Not modelled in WP 2, experiments in WP 3 still pending
- › Approach: compare commercially available bag and candle filters with backwash drum filter

› Candle filters

- › Replacement every month
- › 20 filters needed
- › €120,- per filter



Bollfilter

› Bag filters

- › Replacement every month
- › 6 filters needed
- › €25,- per filter



Dango & Dienenthal

- › Downtime costs (assumption: in fixed O&M)
- › Additional costs associated to NORM: ~€15.000-30.000 per year

Particle filter

increase lifetime
surface equipment (+)


decrease flowrate over
time (-)

filter replacement and
downtime (-)

wastewater (NORM) (-)

› OPTIMIZATION MEASURE BACKWASH DRUMFILTER

- › Commercially available backwash filter, example:
 - › Backwash process activated at defined differential pressure between raw water inlet and clean water outlet (degree of pollution)
 - › 15-20 seconds process finished
 - › During backwashing the filtration process is not interrupted
 - › Longest lifetime: 10 years
 - › Maintenance is negligible, only checking.
 - › ~€38.000,- per filter, two filters needed. One in operation, one filter in standby.



› OPTIMIZATION MEASURE

HYDROGEOFILT FILTER

- › PERFORM: The HydroGeoFilt system has been tested successfully in the laboratory. Long-time onsite tests are, however, still missing.
- › Innovative particle filter with self-cleaning function with ultrasonic device.
- › Now in candle, bag or drum filters: carbonate and iron sulphide precipitations lead to a blocking of the candles.
- › These effects make the normal back wash process impossible and the cartridges have to be manually removed and acidified frequently.
- › The newly developed system shell requires low-maintenance, is efficient and economic in operation.
- › The system will be tested in pilot plant scale.

- › Update: no cost indication available for economic evaluation.



› ECONOMIC EVALUATION

CANDLE AND BAG FILTER VS BACKWASH DRUM FILTER

› Particle filters

› Candle filters

- › Replacement every month
- › 20 filters needed €28.800/yr
- › €120,- per filter

› Bag filters

- › Replacement every month
- › 6 filters needed €1800/yr
- › €25,- per filter

› NORM costs €17.000/yr

_____ +

› Total €47.700/yr

› Backwash drumfilter



- › ~38.000 per filter
- › 2 filters needed €76000/10 yr
- › Lifetime max. 10 yr

› Total €7600/yr

› ECONOMIC EVALUATION

CANDLE AND BAG FILTER VS BACKWASH DRUM FILTER



- › Dutch case
- › Savings by using backwash drumfilter: €39.400/yr
- › Effect on LCOE is minor due to relatively small costs compared to operational costs and pump installation



› ECONOMIC EVALUATION

CANDLE AND BAG FILTER VS BACKWASH DRUM FILTER

- › Danish case
- › Savings by using backwash drumfilter: €39.400/yr
- › Effect on LCOE is minor due to relatively small costs compared to operational costs



› CONCLUSION

- › Modified version of the tool will become publicly available on the PERFORM website
- › Report on economy of optimization measures, data and assumptions
- › Short demo



› **BEDANKT VOOR
UW AANDACHT**

TNO innovation
for life